


12



MISSOURI DEPARTMENT OF NATURAL RESOURCES

P.O. Box 1368 Jefferson City, Missouri 65102 (314) 751-3241

June 1, 1983

Mr. Thomas E. Siedhoff, P.E.  
Assistant Manager  
Environmental Services  
Union Electric Company  
P.O. Box 149  
St. Louis, Missouri 63166

RE: Resource Recovery - Ashley Plant, RR-020

Dear Mr. Siedhoff:

This letter is in response to your letter of May 20, 1983, and our telephone conversation of May 27, 1983, concerning the use of "Navitone", a spent cleaner, as a fuel supplement at the Union Electric - Ashley Plant.

Your request to use the "Navitone" cleaner is approved with the following conditions:

- 1) Generation rate is unknown at this time, but should not exceed 200-250 gallons/year. The spent cleaner is to be removed from service in approximately 55-gallon lots.
- 2) The spent cleaner is to be added to the day tank and mixed with the contents of the tank prior to burning.
- 3) The spent cleaner shall have a heating value of at least 8,000 BTU/pound when it is added to the day tank.
- 4) Records shall be kept in accordance with the present certification on file (RR-020).

If you have any questions regarding this amendment to your resource recovery certification, please contact me at this office.

Sincerely,

*Joe Jansen*

Joe Jansen  
Environmental Engineer  
Waste Management Program

JJ:dr

cc: St. Louis Regional Office  
Mr. Bob Stewart, EPA Region VII

*R. Stewart*

*Steve do you know anything about this?*

*No*

*R. Stewart*

*file*

*File MO D000805499*

RCRA RECORDS CENTER



*not a TSD; 200 gal/yr of Navitone; is recycled for heat content per Joe Jansen 6-8-83*

EPA-ARWM/PMTS

JUN 06 1983

Region VII K.C., MO

Christopher S. Bond Governor  
Fred A. Laiser Director

Division of Environmental Quality  
Robert J. Schreiber Jr., P.E. Director